

GOVERNMENT OF ANDHRA PRADESH
STATE DISASTER RESPONSE & FIRE SERVICES DEPARTMENT

From :
The Director General,
State Disaster Response and Fire Services,
Andhra Pradesh, VIJAYAWADA.

To :
The Management,
M/s Oxford International School,
Opp. I.D. Hospital, Amaravathi Road,
Guntur Town & District.

RC.No.16760/GNT/RFO/2021 (MSB-SR), Dated: -03-2022

Sr.

Sub : A.P. State Disaster Response and Fire Services Department – MSB Section-Issuance of Renewal of No Objection Certificate to the Existing Building of M/s Oxford International School, D.No.144/1, Opp. I.D. Hospital, Amaravathi Road, Guntur Town & District— Regarding.

- Ref :** 1. Occupancy NOC File No.16760/GNT/RFO/2021, Dt : 22-02-2021 of Regional Fire Officer, Southern Region, Vijayawada.
2. Application of M/s Oxford International School, D.No.144/1, Opp. I.D. Hospital, Amaravathi Road, Guntur Town & District.

* * * * *

The Management of M/s Oxford International School, D.No.144/1, Opp. I.D. Hospital, Amaravathi Road, Guntur Town & District has requested to issue Renewal of No Objection Certificate by duly remitting the Renewal Fee towards Fire Precautionary Fee vide reference 2nd cited.

2) The No Objection Certificate for Occupancy was issued vide reference 1st cited to the Existing Building of M/s Oxford International School, D.No.144/1, Opp. I.D. Hospital, Amaravathi Road, Guntur Town & District with Cellar + Ground + 03 upper Floors with Built-up area of 4273.50 Sq.Mtrs. with a Height of 13.20 Mtrs., for Educational Occupancy.

3) The management has submitted the Self-Certification report and stated that the furnished information is correct and it is noticed at any time that the information provided is false, they understand that Renewal NOC deemed may be cancelled by the concerned authority.

4) In view of the above and taking into consideration of the larger public interest and in the context of the COVID-19 pandemic across the country and also based on the Self-Certification submitted by the management, the Renewal of No Objection Certificate is issued to the Existing Building of M/s Oxford EM Upper Primary School, D.No.144/1, Opp. I.D. Hospital, Amaravathi Road, Guntur Town & District with Cellar + Ground + 03 Upper Floors with Built-up area of 4273.50 Sq.Mtrs. with a Height of 13.20 Mtrs., for Educational Occupancy.

(contd.....2p)

5) It is suggested to the Management for providing the following Fire Safety Measures keeping in view of Practicality, Maintenance and Resilience,

Sl. No.	Fire Fighting Equipment	Provided	Available with Nos.	Defect
1	Fire Extinguishers	AHC / CO2 type	45 Nos.	Nil
2	Underground parking / Cellar / Basement	Temperature Sensors connected to "Hooter" and that can be give alerts through Cell Phone instead of Bunklers	Provided	Nil
3	Manual Call Point System	One Number per Floor	05 Nos.	Nil
4	Under Ground Static Water Tank (or) Terrace Water Tank	5,000 Ltrs. (Minimum)	15,000 Ltrs	Nil
5	2 HP (Pump + Electrical Motors connected) @ one per Floor connected to Normal Plumbing System instead of Down Corner / Special Pipes	One per each Floor (Total 05 Floors)	05 Nos.	Nil
6	5 HP (Mobile Pump + Petrol Engine on Wheels connected to Ground Floor Sump).	NA	Nil	Nil

6) Electrical Safety System :

i) Miniature Circuit Breakers, MCB's	: Yes. Provided
ii) No Overloading of Power Sockets	: Yes. Ensured
iii) Whether, 10 years old wiring to be changed specially wherever Mc is there ?	: Yes. Ensured
iv) LED Lights in Closed Rooms, Corridors, Staircases connected to Inverter (Battery)	: Yes. Connected
v) Grounding / Earthing is provided	: Yes. Provided
vi) Lightning Conductor is provided	: Not Applicable
vii) The above shall be certified by authorized Electrical Contractor / Supervisor	: Not Applicable

7) Fire Safety Suggestions :


Sl. No.	As Builder	As Occupant	As Security Personnel
1	All the Fire protection arrangements shall be maintained in good working condition at all time	The Escape / Exit route shall not be kept Locked / Blocked or Encroached	All the occupants must be trained the correct method of operation of the Fire Fighting System installed
2	Any loss of Life or property due to non-functioning of Fire Safety Measures and other Installations shall be the responsibility of the management.	All occupants shall be trained to operate the Fire Safety Equipment during Emergency.	Mock Drills should be conducted once in 03 months for initial two years. Thereafter, once in every 06 months.
3	Addition / Alteration, if any in the Building may be verified by Building Authority.	Mock Drills should be conducted once in 03 months for initial two years. Thereafter, once in every 06 months	All Security Personnel shall be trained to operate the Fire Safety Equipment during Emergency
4	This Annual Periodical Renewal Fire Certificate is only from Fire Safety Point of View	Raise the alarm. If the Fire cannot be controlled, Evacuate the area completely at once with nearest Safe Exit.	Attack the Fire using available Fire Equipment only if you feel capable of controlling it. If not take all steps of isolate the area by closing Doors and Windows.

(contd.....2p)

:: 3 ::

8) This Renewal of No Objection Certificate is valid for a period of Five (05) years from the date of issue of this letter subject to the compliance of above Fire and Electrical Safety Measures. The Owner/Occupier/Builder/Management concerned of the Building shall submit Self Declaration/Certification with regard to working condition of above Fire Safety System every year in the prescribed format and submit/upload the photographs of the Mock Drills conducted in the premises. It is the responsibility of the Builder to maintain the Fire Safety Equipment in good working condition at all times and apply for next Periodical Renewal of No Objection Certificate, duly remitting the User Charges vide G.O.No.90, Home (Prisons & Fire Services) Department Dated:13.08.2021 & G.O.Ns.No.120, Home (Prisons & Fire Services) Department Dated:25.10.2021, two (02) months before expiry of this Renewal of No Objection Certificate.

Yours Sincerely,


Date: 30/3

Director General,
State Disaster Response and Fire Services,
Andhra Pradesh, Vijayawada.

Copy to the Management, M/S Oxford International School, D.No. 144/1, Opp. I.D Hospital, Amaravathi Road, Guntur Town & District.

Copy to Regional Fire Officer, Southern Region, Vijayawada.

Copy to District Fire Officer, Guntur.

Note: In case of any emergency call to 101 or State Fire Control Room-9100108101.